

# Fire Alarm and Life Safety System Inspection Certificate

*For*

ROANOKE REGIONAL  
AIRPORT  
5202 AVIATION DR NW  
ROANOKE, VA 24012

Tested to NFPA 72 Standards

*This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.*

*Annual Inspection  
Inspection Date  
Dec 13, 2019*

Building: ROANOKE REGIONAL AIRPORT  
Contact: ERIN HENDERSON  
Title: SAFETY



Company: Fire & Life Safety America, Inc. - Roanoke  
Contact: Benjamin Lumsden  
Title: Inspector

# Executive Summary

Generated by: BuildingReports.com

Building Information		
<b>Building:</b> ROANOKE REGIONAL AIRPORT	<b>Contact:</b> ERIN HENDERSON	
<b>Address:</b> 5202 AVIATION DR NW	<b>Phone:</b> 540-362-1999	
<b>Address:</b>	<b>Fax:</b>	
<b>City/State/Zip:</b> ROANOKE, VA 24012	<b>Mobile:</b>	
<b>Country:</b> United States of America	<b>Email:</b> ERINH@FLYROA.COM	
Inspection Performed By		
<b>Company:</b> Fire & Life Safety America, Inc. - Roanoke	<b>Inspector:</b> Benjamin Lumsden	
<b>Address:</b> 1407 Mill Race Drive	<b>Phone:</b> 540 728 0445	
<b>Address:</b>	<b>Fax:</b>	
<b>City/State/Zip:</b> Salem, VA 24153	<b>Mobile:</b>	
<b>Country:</b> United States of America	<b>Email:</b> bdlumsden@flsamerica.com	
System Control Unit		
<b>Manufacturer:</b> Simplex	<b>Inspection Date:</b> 12/11/2019	<b>IDC Style:</b>
<b>Model Number:</b> 4020	<b>Install Date:</b> 11/27/2018	<b>SLC Style:</b>
<b>Software Version:</b>	<b>Version Date:</b> 11/29/2018	<b>NAC Style:</b>
<b>Location:</b> Maintenance Garage main panel	<b>Current Protection:</b>	
Monitoring		
<b>Company:</b>	<b>Phone:</b>	<b>Account #:</b>
Central Station Signal Verification		
<b>Type:</b> Digital Communicator	<b>Mfg:</b> Honeywell	<b>Model #:</b>
<b>Test Time/Date:</b> 12/10/19 2:08:30 PM	<b>Restore Time:</b>	vista-128fbpn

Inspection Summary								
Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Control	51	11.89%	51	100.00%	50	98.04%	1	1.96%
Auxiliary	1	0.23%	1	100.00%	1	100.00%	0	0%
Initiating	371	86.48%	371	100.00%	371	100.00%	0	0%
Indicating	6	1.40%	6	100.00%	5	83.33%	1	16.67%
<b>Totals</b>	<b>429</b>	<b>100%</b>	<b>429</b>	<b>100.00%</b>	<b>427</b>	<b>99.53%</b>	<b>2</b>	<b>0.47%</b>

Certification	
Company: Fire & Life Safety America, Inc. – Roanoke	Building: ROANOKE REGIONAL AIRPORT
Inspector: Benjamin Lumsden	Contact: ERIN HENDERSON
	
Signed: Dec 13, 2019 9:19:16 AM	Signed: Dec 12, 2019 4:08:14 PM

Benjamin Lumsden Certifications	
Certification Type	Number
ABPA Backflow Assembly Tester	

# Discrepancy Report

Generated by: *BuildingReports.com*

<b>Building: ROANOKE REGIONAL AIRPORT    Control Panel: 1</b>				
<p><i>The Discrepancy Report consolidates each discrepancy listed within the various Testing sections of your Inspection. Discrepancies are listed by Category, and grouped by device type. The description of the problem is provided and where appropriate, code references are listed for your convenience. Any item that was inspected that is subject to a recall or part of a manufacturer's replacement/upgrade program is included.</i></p>				
<b>Device Type</b>	<b>Manufacturer</b>	<b>ModelNumber</b>	<b>Date</b>	<b>Qty</b>
<b><i>Items listed for Recall or Replacement/Upgrade</i></b>				
No items found during this inspection.				
<b>🔍 ScanID</b>	<b>📍 Location</b>	<b>🔑 Problem</b>	<b>Address</b>	<b>📖 Reference</b>
<b><i>Control</i></b>				
<b>Battery</b>				
52328915	Hanger 15	Failed Test	1	NFPA72 Table 14.4.3.2 (9)c(1)
<b><i>Indicating</i></b>				
<b>Horn/Strobe</b>				
52328910	Building 51 Building	Failed Operation	1	NFPA72 14.2.2.2.2
<b><i>Code References</i></b>				
NFPA72 Table 14.4.3.2 (9)c(1)	Batteries shall be replaced in accordance with the recommendations of the alarm equipment manufacturer or when the recharged battery voltage or current falls below the manufacturer's recommendations			
NFPA72 14.2.2.2.2	System deficiencies shall be corrected.			

# Proposed Solutions Report

Generated by: *BuildingReports.com*

Building: ROANOKE REGIONAL AIRPORT				Control Panel: 1	
<p><i>The Proposed Solution Report provides a solution for each discrepancy listed on the Discrepancy Report. Provide a check mark where indicated to approve repairs listed within the report. Items listed as T/M are available for repair on a Time and Materials basis.</i></p>					
ScanID	Location	Solution	Model #	Cost	Fix
<b><i>Control</i></b>					
<b>Battery</b>					
52328915	Hanger 15	Replace		T/M	<input type="checkbox"/>
<b><i>Indicating</i></b>					
<b>Horn/Strobe</b>					
52328910	Building 51 Building	See notes/recommendations		T/M	<input type="checkbox"/>
				PO #: (none)	T/M

# Notes & Recommendations

Generated by: *BuildingReports.com*

**Building: ROANOKE REGIONAL AIRPORT**

*The Notes & Recommendations Report details additional inspection notes made by the Inspectors during the course of the building inspection. Notes are grouped by Category.*

***General Note***

The smoke detectors at the TSA bag check conveyor fire doors did not close the doors upon activation of the smoke detector.

**Building: ROANOKE REGIONAL AIRPORT    Control Panel: 1**

ScanID	Note	Device Type	Location	Comment
<b><i>Indicating</i></b>				
52328910	2	Horn/Strobe	Building 51 Building	Failed Operation
Horn devices in basement sounding at a low audible level and the strobes do not flash on all but two devices.				
52328821	3	Horn/Strobe	Terminal Main building	Passed
Horn/strobe at very end of the concourse does not function.				
<b><i>Initiating</i></b>				
52328682	4	Heat Detector	Terminal elevator #3 pit	Passed
Did not shunt trip the elevator				

# Inspection & Testing

Generated by: BuildingReports.com

Building: ROANOKE REGIONAL AIRPORT    Control Panel: 1				
<i>The Inspection &amp; Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time &amp; date at which testing occurred.</i>				
Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
<b>Control</b>				
Annunciator	Building 51 side door @ room 1	Tested	9:33:45 AM	12/10/2019
Battery	ARFF Station main panel	Tested	2:02:40 PM	12/10/2019
Battery	ARFF Station main panel	Tested	2:03:59 PM	12/10/2019
Battery	ARFF Station main panel	Tested	2:08:48 PM	12/10/2019
Battery	ARFF Station main panel	Tested	2:09:05 PM	12/10/2019
Battery	Building 51 main panel	Tested	11:03:45 AM	12/10/2019
Battery	Building 51 main panel	Tested	11:03:49 AM	12/10/2019
Battery	Building 51 nac	Tested	10:47:32 AM	12/10/2019
Battery	Building 51 nac	Tested	10:48:03 AM	12/10/2019
Battery	Hanger 14	Tested	11:23:34 AM	12/11/2019
Battery	Hanger 14	Tested	11:23:39 AM	12/11/2019
Battery	Hanger 15	Tested	11:24:15 AM	12/11/2019
Battery	Maintenance Garage main panel	Tested	10:18:54 AM	12/11/2019
Battery	Maintenance Garage main panel	Tested	10:23:09 AM	12/11/2019
Battery	Terminal check point	Tested	3:07:54 PM	12/12/2019
Battery	Terminal check point	Tested	3:08:41 PM	12/12/2019
Battery	Terminal law enforcement office	Tested	3:17:13 PM	12/12/2019
Battery	Terminal law enforcement office	Tested	3:17:56 PM	12/12/2019
Battery	Terminal soc rm	Tested	2:58:39 PM	12/12/2019
Battery	Terminal soc rm	Tested	2:59:48 PM	12/12/2019
Communicator	ARFF Station main panel	Tested	2:08:30 PM	12/10/2019
<b>Indicating</b>				
Horn/Strobe	ARFF Station building	Tested	1:54:09 PM	12/10/2019
Horn/Strobe	Hanger 14	Tested	11:23:44 AM	12/11/2019
Horn/Strobe	Hanger 15	Tested	11:24:20 AM	12/11/2019
Horn/Strobe	Maintenance Garage maintenance building	Tested	9:51:32 AM	12/11/2019
Horn/Strobe	Terminal Main building	Tested	2:18:29 PM	12/12/2019
<b>Initiating</b>				
Duct Detector	Building 51 air room back right conner	Tested	9:51:15 AM	12/10/2019
Duct Detector	Building 51 air room back right conner	Tested	9:59:44 AM	12/10/2019
Duct Detector	Building 51 duct off server rm	Tested	10:05:47 AM	12/10/2019
Duct Detector	Building 51 duct off server rm	Tested	10:15:50 AM	12/10/2019
Duct Detector	Building 51 room #1	Tested	9:46:28 AM	12/10/2019
Duct Detector	Maintenance Garage @ warehouse center door	Tested	3:57:52 PM	12/11/2019
Duct Detector	Maintenance Garage mezzanine storage	Tested	9:47:23 AM	12/11/2019
Duct Detector	Terminal area b penthouse east	Tested	2:43:55 PM	12/12/2019
Duct Detector	Terminal area b penthouse east	Tested	2:43:59 PM	12/12/2019

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Duct Detector	Terminal area b penthouse east	Tested	2:44:04 PM	12/12/2019
Duct Detector	Terminal lwr area a ah-3 rm	Tested	2:44:19 PM	12/12/2019
Duct Detector	Terminal lwr area a ah-3 rm	Tested	2:44:24 PM	12/12/2019
Duct Detector	Terminal lwr area a ah-3 rm	Tested	2:44:28 PM	12/12/2019
Duct Detector	Terminal lwr area a ah-4 equip rm	Tested	2:44:08 PM	12/12/2019
Duct Detector	Terminal lwr area a ah-4 equip rm	Tested	2:44:12 PM	12/12/2019
Duct Detector	Terminal penthouse lvl c	Tested	2:43:36 PM	12/12/2019
Duct Detector	Terminal penthouse lvl c	Tested	2:43:40 PM	12/12/2019
Duct Detector	Terminal penthouse lvl c	Tested	2:43:45 PM	12/12/2019
Heat Detector	ARFF Station Bay Area row #1	Tested	1:53:06 PM	12/10/2019
Heat Detector	ARFF Station Bay Area row #1	Tested	1:53:10 PM	12/10/2019
Heat Detector	ARFF Station Bay Area row #1	Tested	1:53:15 PM	12/10/2019
Heat Detector	ARFF Station Bay Area row #2	Tested	1:53:20 PM	12/10/2019
Heat Detector	ARFF Station Bay Area row #2	Tested	1:53:24 PM	12/10/2019
Heat Detector	ARFF Station Bay Area row #2	Tested	1:53:28 PM	12/10/2019
Heat Detector	ARFF Station Bay Area row #3	Tested	1:53:32 PM	12/10/2019
Heat Detector	ARFF Station Bay Area row #3	Tested	1:53:37 PM	12/10/2019
Heat Detector	ARFF Station Bay Area row #3	Tested	1:53:42 PM	12/10/2019
Heat Detector	ARFF Station Bay Area row #4	Tested	1:53:46 PM	12/10/2019
Heat Detector	ARFF Station Bay Area row #4	Tested	1:53:53 PM	12/10/2019
Heat Detector	ARFF Station Bay Area row #4	Tested	1:54:00 PM	12/10/2019
Heat Detector	ARFF Station laundry rm 112	Tested	1:52:20 PM	12/10/2019
Heat Detector	Maintenance Garage @ Crane	Tested	9:45:43 AM	12/11/2019
Heat Detector	Maintenance Garage @ Crane	Tested	9:45:47 AM	12/11/2019
Heat Detector	Maintenance Garage @ Crane	Tested	9:45:52 AM	12/11/2019
Heat Detector	Maintenance Garage @ Crane wallside	Tested	9:45:58 AM	12/11/2019
Heat Detector	Maintenance Garage @ Crane wallside	Tested	9:46:03 AM	12/11/2019
Heat Detector	Maintenance Garage @ Crane wallside	Tested	9:46:07 AM	12/11/2019
Heat Detector	Maintenance Garage @ light front roll up door	Tested	9:45:10 AM	12/11/2019
Heat Detector	Maintenance Garage @ mezzanine	Tested	9:45:06 AM	12/11/2019
Heat Detector	Maintenance Garage @ Side front roll up door	Tested	9:46:31 AM	12/11/2019
Heat Detector	Maintenance Garage @ Side front roll up door	Tested	9:46:35 AM	12/11/2019
Heat Detector	Maintenance Garage @ Side front roll up door	Tested	9:46:39 AM	12/11/2019
Heat Detector	Maintenance Garage @ Side front roll up door wallside	Tested	9:46:13 AM	12/11/2019
Heat Detector	Maintenance Garage @ Side front roll up door wallside	Tested	9:46:24 AM	12/11/2019
Heat Detector	Maintenance Garage @ Side front roll up door wallside	Tested	9:46:27 AM	12/11/2019
Heat Detector	Maintenance Garage @ side roll up door	Tested	9:45:39 AM	12/11/2019
Heat Detector	Maintenance Garage @ wet system	Tested	9:45:02 AM	12/11/2019
Heat Detector	Maintenance Garage @ work shop	Tested	9:45:14 AM	12/11/2019
Heat Detector	Maintenance Garage @ work shop	Tested	9:45:20 AM	12/11/2019
Heat Detector	Maintenance Garage @front entrance roll up door	Tested	9:44:59 AM	12/11/2019
Heat Detector	Maintenance Garage above fire panel	Tested	9:44:55 AM	12/11/2019
Heat Detector	Maintenance Garage lunch room	Tested	9:52:29 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #1 @ center door	Tested	9:48:22 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #1 @	Tested	9:48:26 AM	12/11/2019



Device Type	Location	Service	Time	Date
<i>Passed</i>				
Heat Detector	center door Maintenance Garage warehouse row #1 @	Tested	9:48:34 AM	12/11/2019
Heat Detector	center door Maintenance Garage warehouse row #1 @	Tested	9:48:38 AM	12/11/2019
Heat Detector	center door Maintenance Garage warehouse row #1 @	Tested	9:48:53 AM	12/11/2019
Heat Detector	center door Maintenance Garage warehouse row #1 @	Tested	9:48:59 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #2	Tested	9:49:03 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #2	Tested	9:49:07 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #2	Tested	9:49:12 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #2	Tested	9:49:17 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #2	Tested	9:49:21 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #2	Tested	9:49:24 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #3	Tested	9:49:28 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #3	Tested	9:49:32 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #3	Tested	9:49:37 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #3	Tested	9:49:47 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #3	Tested	9:49:51 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #3	Tested	9:49:56 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #4	Tested	9:50:02 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #4	Tested	9:50:06 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #4	Tested	9:50:11 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #4	Tested	9:50:15 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #4	Tested	9:50:18 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #4	Tested	9:50:22 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #5	Tested	9:50:26 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #5	Tested	9:50:38 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #5	Tested	9:50:41 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #5	Tested	9:50:45 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #5	Tested	9:50:50 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #5	Tested	9:50:54 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #6	Tested	9:50:58 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #6	Tested	9:51:04 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #6	Tested	9:51:07 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #6	Tested	9:51:12 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #6	Tested	9:51:23 AM	12/11/2019
Heat Detector	Maintenance Garage warehouse row #6	Tested	9:51:28 AM	12/11/2019
Heat Detector	Terminal elevator #3 pit	Tested	10:49:46 PM	12/11/2019
Heat Detector	Terminal freight elevator area c pit	Tested	10:50:13 PM	12/11/2019
Heat Detector	Terminal lwr area a elevator 5 and 6 equip rm	Tested	10:48:38 PM	12/11/2019
Heat Detector	Terminal lwr area a elevator 5 and 6 pit	Tested	10:48:18 PM	12/11/2019
Heat Detector	Terminal lwr lvl c freight elevator rm	Tested	10:50:24 PM	12/11/2019
Heat Detector	Terminal main elevator pit	Tested	9:05:53 AM	12/12/2019
Heat Detector	Terminal up lvl c main elevator control room	Tested	2:17:59 PM	12/12/2019
Heat Detector	Terminal up lvl c main elevator shaft	Tested	2:17:40 PM	12/12/2019
Heat Detector	Terminal upper lvl c concessions kitchen area	Tested	2:17:00 PM	12/12/2019
Heat Detector	Terminal upper lvl c concessions serve area	Tested	2:16:55 PM	12/12/2019
Heat Detector	Terminal upper lvl c elevator shaft	Tested	10:50:39 PM	12/11/2019

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Heat Detector	Terminal upr area a concrs. elevator shaft	Tested	10:48:12 PM	12/11/2019
Heat Detector	Terminal upr area a elevator #3 equip rm	Tested	10:49:42 PM	12/11/2019
Heat Detector	Terminal upr area a elevator #3 shaft	Tested	10:49:14 PM	12/11/2019
Heat Detector	Terminal upr area a macalisters cafe	Tested	2:17:05 PM	12/12/2019
Pull Station	ARFF Station exit door @ Decon 149	Tested	1:52:49 PM	12/10/2019
Pull Station	ARFF Station exit door @ kitchen	Tested	1:52:00 PM	12/10/2019
Pull Station	ARFF Station exit door rear	Tested	1:52:46 PM	12/10/2019
Pull Station	ARFF Station front entrance	Tested	1:52:34 PM	12/10/2019
Pull Station	ARFF Station outside storage	Tested	1:52:53 PM	12/10/2019
Pull Station	ARFF Station side exit door	Tested	12:36:10 PM	12/10/2019
Pull Station	ARFF Station side exit door @ dorm rm 133 hallway	Tested	1:51:48 PM	12/10/2019
Pull Station	Building 51 @ double door	Tested	10:04:33 AM	12/10/2019
Pull Station	Building 51 back door room 1	Tested	9:35:17 AM	12/10/2019
Pull Station	Building 51 basement back door	Tested	10:40:37 AM	12/10/2019
Pull Station	Building 51 basement back door center	Tested	10:32:10 AM	12/10/2019
Pull Station	Building 51 basement back door eating area	Tested	10:41:18 AM	12/10/2019
Pull Station	Building 51 bottom of stairs basement	Tested	10:17:59 AM	12/10/2019
Pull Station	Building 51 center door room #1	Tested	10:16:00 AM	12/10/2019
Pull Station	Building 51 exit @stairs	Tested	10:17:13 AM	12/10/2019
Pull Station	Building 51 front right door	Tested	10:01:18 AM	12/10/2019
Pull Station	Building 51 rear exit door m-2	Tested	9:50:53 AM	12/10/2019
Pull Station	Building 51 side door @ room 1	Tested	9:31:36 AM	12/10/2019
Pull Station	Building 51 side door @ server room	Tested	10:04:55 AM	12/10/2019
Pull Station	Building 51 side door room 1	Tested	9:33:41 AM	12/10/2019
Pull Station	Hanger 14 side door	Tested	11:23:16 AM	12/11/2019
Pull Station	Hanger 15 side door	Tested	11:23:55 AM	12/11/2019
Pull Station	Maintenance Garage @ back door exit	Tested	9:48:08 AM	12/11/2019
Pull Station	Maintenance Garage @ back side door exit	Tested	9:48:00 AM	12/11/2019
Pull Station	Maintenance Garage @ middle door exit	Tested	9:47:56 AM	12/11/2019
Pull Station	Maintenance Garage @ parts room exit	Tested	9:47:48 AM	12/11/2019
Pull Station	Maintenance Garage @ side door exit	Tested	9:47:52 AM	12/11/2019
Pull Station	Maintenance Garage @side roll up door	Tested	9:47:37 AM	12/11/2019
Pull Station	Maintenance Garage front hallway	Tested	9:52:42 AM	12/11/2019
Pull Station	Maintenance Garage front roll up door	Tested	9:47:27 AM	12/11/2019
Pull Station	Maintenance Garage mezzanine storage	Tested	9:47:18 AM	12/11/2019
Pull Station	Maintenance Garage storage room exit	Tested	9:47:44 AM	12/11/2019
Pull Station	Terminal B sec main entry @ revolving drs	Tested	2:21:04 PM	12/12/2019
Pull Station	Terminal Lower lvl C 102 west @ T156	Tested	2:20:48 PM	12/12/2019
Pull Station	Terminal Lower lvl C 102 west @ T157	Tested	2:20:44 PM	12/12/2019
Pull Station	Terminal Lower lvl C Bag claim area	Tested	2:20:52 PM	12/12/2019
Pull Station	Terminal Lower lvl C Bag claim area	Tested	2:20:56 PM	12/12/2019
Pull Station	Terminal Lower lvl C T102 west	Tested	2:21:00 PM	12/12/2019
Pull Station	Terminal lwr area a ah-4 equip rm	Tested	2:24:21 PM	12/12/2019
Pull Station	Terminal lwr area a airline ops	Tested	2:25:13 PM	12/12/2019
Pull Station	Terminal lwr area a commuter gate	Tested	2:23:24 PM	12/12/2019
Pull Station	Terminal lwr area a commuter gate	Tested	2:23:29 PM	12/12/2019
Pull Station	Terminal lwr area a commuter stairwell	Tested	2:23:18 PM	12/12/2019
Pull Station	Terminal lwr area a exit	Tested	2:24:27 PM	12/12/2019
Pull Station	Terminal lwr area a exit	Tested	2:24:32 PM	12/12/2019

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Pull Station	Terminal lwr area a exit	Tested	2:24:50 PM	12/12/2019
Pull Station	Terminal lwr area a gate 2 stairway	Tested	2:24:38 PM	12/12/2019
Pull Station	Terminal lwr area a gate 3 exit	Tested	2:24:13 PM	12/12/2019
Pull Station	Terminal lwr area a gate 5 stairway exit	Tested	2:25:05 PM	12/12/2019
Pull Station	Terminal lwr area a gate 6 hall exit	Tested	2:24:59 PM	12/12/2019
Pull Station	Terminal lwr area a soc exit	Tested	2:24:44 PM	12/12/2019
Pull Station	Terminal Lwr area B east lobby	Tested	2:21:08 PM	12/12/2019
Pull Station	Terminal Lwr area B east lobby	Tested	2:21:13 PM	12/12/2019
Pull Station	Terminal Lwr area B east stairway	Tested	2:21:17 PM	12/12/2019
Pull Station	Terminal Lwr lvl B bag east make up exit	Tested	2:21:59 PM	12/12/2019
Pull Station	Terminal Lwr lvl B bag make up	Tested	2:21:53 PM	12/12/2019
Pull Station	Terminal Lwr lvl B main switch rm	Tested	2:22:07 PM	12/12/2019
Pull Station	Terminal lwr lvl b mechanical rm	Tested	2:39:08 PM	12/12/2019
Pull Station	Terminal Lwr lvl B ticket area	Tested	2:21:22 PM	12/12/2019
Pull Station	Terminal Lwr lvl B ticket area	Tested	2:21:47 PM	12/12/2019
Pull Station	Terminal Lwr lvl B ticket hallway	Tested	2:21:28 PM	12/12/2019
Pull Station	Terminal Lwr lvl B ticket hallway	Tested	2:21:32 PM	12/12/2019
Pull Station	Terminal Lwr lvl B ticket hallway	Tested	2:21:38 PM	12/12/2019
Pull Station	Terminal Lwr lvl c secr/I'd hallway	Tested	2:22:33 PM	12/12/2019
Pull Station	Terminal Lwr lvl c west hallway	Tested	2:22:18 PM	12/12/2019
Pull Station	Terminal Lwr lvl c west hallway	Tested	2:22:23 PM	12/12/2019
Pull Station	Terminal up lvl b hall @ gift shop	Tested	2:20:17 PM	12/12/2019
Pull Station	Terminal upr area a exit	Tested	2:23:48 PM	12/12/2019
Pull Station	Terminal upr area a exit	Tested	2:23:56 PM	12/12/2019
Pull Station	Terminal upr area a exit	Tested	2:24:01 PM	12/12/2019
Pull Station	Terminal upr area a exit	Tested	2:24:07 PM	12/12/2019
Pull Station	Terminal upr area a gate 5a exit	Tested	2:23:43 PM	12/12/2019
Pull Station	Terminal upr level a concrs. elevator	Tested	2:23:36 PM	12/12/2019
Pull Station	Terminal upr lvl b hall @ up escalator	Tested	2:22:55 PM	12/12/2019
Pull Station	Terminal upr lvl b rear hall comm. office	Tested	2:23:13 PM	12/12/2019
Pull Station	Terminal upr lvl b stairs @comm. office	Tested	2:23:07 PM	12/12/2019
Pull Station	Terminal upr lvl c rest. kitchen hall	Tested	2:22:38 PM	12/12/2019
Pull Station	Terminal upr lvl c rest. kitchen hall	Tested	2:22:47 PM	12/12/2019
Pull Station	Terminal upr lvl c west balcony hall	Tested	2:22:43 PM	12/12/2019
Smoke Detector	ARFF Station above fire panel	Tested/Cleaned	1:50:51 PM	12/10/2019
Smoke Detector	ARFF Station common area	Tested/Cleaned	1:52:08 PM	12/10/2019
Smoke Detector	ARFF Station common area	Tested/Cleaned	1:52:12 PM	12/10/2019
Smoke Detector	ARFF Station decon station 149	Tested/Cleaned	1:53:02 PM	12/10/2019
Smoke Detector	ARFF Station dorm rm 120	Tested/Cleaned	12:35:37 PM	12/10/2019
Smoke Detector	ARFF Station dorm rm 133	Tested/Cleaned	1:51:38 PM	12/10/2019
Smoke Detector	ARFF Station dorm rm 137	Tested/Cleaned	1:51:23 PM	12/10/2019
Smoke Detector	ARFF Station electrical rm 128	Tested/Cleaned	1:51:44 PM	12/10/2019
Smoke Detector	ARFF Station exercise rm	Tested/Cleaned	1:51:27 PM	12/10/2019
Smoke Detector	ARFF Station front entrance	Tested/Cleaned	1:52:30 PM	12/10/2019
Smoke Detector	ARFF Station hallway @ kitchen	Tested/Cleaned	1:52:04 PM	12/10/2019
Smoke Detector	ARFF Station hallway @ dorm rm 120	Tested/Cleaned	12:35:13 PM	12/10/2019
Smoke Detector	ARFF Station hallway @ dorm rm 124	Tested/Cleaned	12:36:54 PM	12/10/2019
Smoke Detector	ARFF Station hallway @ dorm rm 124	Tested/Cleaned	1:50:57 PM	12/10/2019
Smoke Detector	ARFF Station hallway @ dorm rm 133	Tested/Cleaned	1:51:35 PM	12/10/2019
Smoke Detector	ARFF Station hallway @ dorm rm 137	Tested/Cleaned	1:51:19 PM	12/10/2019

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Smoke Detector	ARFF Station hallway @ rm 109	Tested/Cleaned	1:51:56 PM	12/10/2019
Smoke Detector	ARFF Station hallway @ rm 112	Tested/Cleaned	1:52:16 PM	12/10/2019
Smoke Detector	ARFF Station hallway @ rm 112	Tested/Cleaned	1:52:25 PM	12/10/2019
Smoke Detector	ARFF Station hallway @ watch/alarm 118	Tested/Cleaned	1:51:01 PM	12/10/2019
Smoke Detector	ARFF Station mechanical rm 202	Tested/Cleaned	1:52:42 PM	12/10/2019
Smoke Detector	ARFF Station middle hallway	Tested/Cleaned	1:51:09 PM	12/10/2019
Smoke Detector	ARFF Station outside storage	Tested/Cleaned	1:52:57 PM	12/10/2019
Smoke Detector	ARFF Station server rm	Tested/Cleaned	1:51:04 PM	12/10/2019
Smoke Detector	ARFF Station side exit door	Tested/Cleaned	1:51:14 PM	12/10/2019
Smoke Detector	ARFF Station storage rm 129	Tested/Cleaned	1:51:30 PM	12/10/2019
Smoke Detector	ARFF Station storage rm 136	Tested/Cleaned	1:51:52 PM	12/10/2019
Smoke Detector	Building 51 basement electrical rm	Tested/Cleaned	10:21:36 AM	12/10/2019
Smoke Detector	Building 51 basement electrical rm	Tested/Cleaned	10:37:17 AM	12/10/2019
Smoke Detector	Building 51 basement telephone rm	Tested/Cleaned	10:21:31 AM	12/10/2019
Smoke Detector	Building 51 elevator	Tested/Cleaned	10:03:05 AM	12/10/2019
Smoke Detector	Building 51 elevator	Tested/Cleaned	10:20:16 AM	12/10/2019
Smoke Detector	Building 51 mechanical room	Tested/Cleaned	10:20:23 AM	12/10/2019
Smoke Detector	Hanger 14	Tested/Cleaned	11:23:20 AM	12/11/2019
Smoke Detector	Hanger 14	Tested/Cleaned	11:23:24 AM	12/11/2019
Smoke Detector	Hanger 15	Tested/Cleaned	11:23:59 AM	12/11/2019
Smoke Detector	Hanger 15	Tested/Cleaned	11:24:03 AM	12/11/2019
Smoke Detector	Maintenance Garage @ mezzanine	Tested/Cleaned	9:46:45 AM	12/11/2019
Smoke Detector	Maintenance Garage @ mezzanine	Tested/Cleaned	9:46:51 AM	12/11/2019
Smoke Detector	Maintenance Garage @ mezzanine	Tested/Cleaned	9:46:55 AM	12/11/2019
Smoke Detector	Maintenance Garage @ mezzanine	Tested/Cleaned	9:46:59 AM	12/11/2019
Smoke Detector	Maintenance Garage @ Parts room	Tested/Cleaned	9:45:29 AM	12/11/2019
Smoke Detector	Maintenance Garage @ Parts room	Tested/Cleaned	9:45:33 AM	12/11/2019
Smoke Detector	Maintenance Garage facility and grounds office	Tested/Cleaned	9:51:41 AM	12/11/2019
Smoke Detector	Maintenance Garage front hallway	Tested/Cleaned	9:52:34 AM	12/11/2019
Smoke Detector	Maintenance Garage front hallway @ men's room	Tested/Cleaned	9:51:37 AM	12/11/2019
Smoke Detector	Maintenance Garage front office	Tested/Cleaned	9:52:38 AM	12/11/2019
Smoke Detector	Maintenance Garage laundry room	Tested/Cleaned	9:51:45 AM	12/11/2019
Smoke Detector	Maintenance Garage lunch room	Tested/Cleaned	9:52:23 AM	12/11/2019
Smoke Detector	Maintenance Garage Mechanic office	Tested/Cleaned	9:47:31 AM	12/11/2019
Smoke Detector	Maintenance Garage mezzanine storage	Tested/Cleaned	9:47:03 AM	12/11/2019
Smoke Detector	Maintenance Garage mezzanine storage	Tested/Cleaned	9:47:07 AM	12/11/2019
Smoke Detector	Terminal area b penthouse east	Tested/Cleaned	2:43:50 PM	12/12/2019
Smoke Detector	Terminal Electric rm behind copy rm	Tested/Cleaned	2:19:39 PM	12/12/2019
Smoke Detector	Terminal elevator #3 pit	Tested/Cleaned	10:49:52 PM	12/11/2019
Smoke Detector	Terminal finance office hallway	Tested/Cleaned	9:09:47 AM	12/13/2019
Smoke Detector	Terminal freight elevator area c pit	Tested/Cleaned	10:50:09 PM	12/11/2019
Smoke Detector	Terminal lower area b east stairwell	Tested/Cleaned	2:19:55 PM	12/12/2019
Smoke Detector	Terminal lower lvl c main elevator. control rm	Tested/Cleaned	2:17:53 PM	12/12/2019
Smoke Detector	Terminal lower lvl c T102 west elev lobby	Tested/Cleaned	2:17:46 PM	12/12/2019
Smoke Detector	Terminal lwr area a	Tested/Cleaned	2:40:04 PM	12/12/2019
Smoke Detector	Terminal lwr area a	Tested/Cleaned	2:40:07 PM	12/12/2019
Smoke Detector	Terminal lwr area a	Tested/Cleaned	2:40:12 PM	12/12/2019
Smoke Detector	Terminal lwr area a ah-3 rm	Tested/Cleaned	2:41:19 PM	12/12/2019
Smoke Detector	Terminal lwr area a ah-3 rm	Tested/Cleaned	2:41:24 PM	12/12/2019

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Smoke Detector	Terminal lwr area a ah-4 elec panel rm	Tested/Cleaned	2:40:27 PM	12/12/2019
Smoke Detector	Terminal lwr area a ah-4 equip rm	Tested/Cleaned	2:40:17 PM	12/12/2019
Smoke Detector	Terminal lwr area a ah-4 equip rm	Tested/Cleaned	2:40:22 PM	12/12/2019
Smoke Detector	Terminal lwr area a airline ops	Tested/Cleaned	2:41:53 PM	12/12/2019
Smoke Detector	Terminal lwr area a commuter gate	Tested/Cleaned	2:44:46 PM	12/12/2019
Smoke Detector	Terminal lwr area a elev #3 equip rm	Tested/Cleaned	10:49:37 PM	12/11/2019
Smoke Detector	Terminal lwr area a elev 5 and 6 equip rm	Tested/Cleaned	10:48:28 PM	12/11/2019
Smoke Detector	Terminal lwr area a elevator 5 and 6 pit	Tested/Cleaned	10:48:24 PM	12/11/2019
Smoke Detector	Terminal lwr area a elevator equip rm	Tested/Cleaned	2:40:32 PM	12/12/2019
Smoke Detector	Terminal lwr area a main facp soc	Tested/Cleaned	9:10:45 AM	12/13/2019
Smoke Detector	Terminal lwr area a soc rm	Tested/Cleaned	9:10:49 AM	12/13/2019
Smoke Detector	Terminal lwr area a soc server rm	Tested/Cleaned	9:10:54 AM	12/13/2019
Smoke Detector	Terminal lwr lvl b airline office	Tested/Cleaned	2:31:19 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b boiler rm	Tested/Cleaned	2:28:57 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b east end eds	Tested/Cleaned	2:30:01 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b east end eds	Tested/Cleaned	2:30:09 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b east ticket	Tested/Cleaned	2:27:00 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b east ticket	Tested/Cleaned	2:27:06 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b east ticket	Tested/Cleaned	2:27:11 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b east ticket	Tested/Cleaned	2:27:15 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b east ticket	Tested/Cleaned	2:27:21 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b east ticket	Tested/Cleaned	2:27:26 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b east ticket	Tested/Cleaned	2:27:31 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b east ticket	Tested/Cleaned	2:27:39 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b escalator hall	Tested/Cleaned	2:29:11 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b main switch rm	Tested/Cleaned	2:29:01 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b mechanical rm	Tested/Cleaned	2:19:44 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b mechanical rm	Tested/Cleaned	2:28:53 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b pump rm	Tested/Cleaned	2:29:07 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b ticket area	Tested/Cleaned	2:29:25 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b ticket area	Tested/Cleaned	2:29:30 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b ticket area	Tested/Cleaned	2:29:39 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b ticket area	Tested/Cleaned	2:29:44 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b ticket hallway	Tested/Cleaned	2:31:15 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b ticket hallway	Tested/Cleaned	2:31:23 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b ticket hallway	Tested/Cleaned	2:31:27 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b ticket hallway	Tested/Cleaned	2:31:32 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b west end eds	Tested/Cleaned	2:29:15 PM	12/12/2019
Smoke Detector	Terminal lwr lvl b west end eds	Tested/Cleaned	2:29:20 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c ambassador rm	Tested/Cleaned	1:51:37 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c bag claim area	Tested/Cleaned	2:27:56 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c bag claim area	Tested/Cleaned	2:28:04 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c bag claim area	Tested/Cleaned	2:28:10 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c concession area	Tested/Cleaned	9:08:59 AM	12/13/2019
Smoke Detector	Terminal lwr lvl c concessions @drink Mach.	Tested/Cleaned	2:34:25 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c freight elevator rm	Tested/Cleaned	10:50:17 PM	12/11/2019
Smoke Detector	Terminal lwr lvl c main elevator	Tested/Cleaned	2:30:32 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c main elevator	Tested/Cleaned	2:30:38 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c restrur. front area	Tested/Cleaned	2:34:29 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c restrur. front area	Tested/Cleaned	9:08:54 AM	12/13/2019

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Smoke Detector	Terminal lwr lvl c t102 west	Tested/Cleaned	2:26:10 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c t102 west	Tested/Cleaned	2:26:14 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c t102 west	Tested/Cleaned	2:26:18 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c t102 west	Tested/Cleaned	2:26:22 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c t102 west	Tested/Cleaned	2:26:26 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c t102 west	Tested/Cleaned	2:26:48 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c t102 west	Tested/Cleaned	2:26:52 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c t102 west	Tested/Cleaned	2:26:56 PM	12/12/2019
Smoke Detector	Terminal lwr lvl c west balcony hall	Tested/Cleaned	9:09:08 AM	12/13/2019
Smoke Detector	Terminal lwr lvl c west balcony hall	Tested/Cleaned	9:09:12 AM	12/13/2019
Smoke Detector	Terminal lwr lvl c west balcony hall	Tested/Cleaned	9:09:16 AM	12/13/2019
Smoke Detector	Terminal lwr lvl c west elevator hall	Tested/Cleaned	9:10:21 AM	12/13/2019
Smoke Detector	Terminal lwr lvl c west freight elevator lobby	Tested/Cleaned	10:50:05 PM	12/11/2019
Smoke Detector	Terminal lwr lvl c west wing tsa offices	Tested/Cleaned	9:09:21 AM	12/13/2019
Smoke Detector	Terminal lwr lvl c west wing tsa offices	Tested/Cleaned	9:09:25 AM	12/13/2019
Smoke Detector	Terminal lwr lvl c west wing tsa offices	Tested/Cleaned	9:09:33 AM	12/13/2019
Smoke Detector	Terminal main elevator pit	Tested/Cleaned	9:05:46 AM	12/12/2019
Smoke Detector	Terminal main remark room	Tested/Cleaned	2:19:49 PM	12/12/2019
Smoke Detector	Terminal penthouse lvl c	Tested/Cleaned	2:43:32 PM	12/12/2019
Smoke Detector	Terminal up lvl c concession kitchen area	Tested/Cleaned	9:10:12 AM	12/13/2019
Smoke Detector	Terminal up lvl c hallway fiancé west	Tested/Cleaned	9:09:42 AM	12/13/2019
Smoke Detector	Terminal up lvl c hallway finance east	Tested/Cleaned	9:09:52 AM	12/13/2019
Smoke Detector	Terminal up lvl c main elevator lobby	Tested/Cleaned	2:17:31 PM	12/12/2019
Smoke Detector	Terminal up lvl c main elevator shaft	Tested/Cleaned	2:17:35 PM	12/12/2019
Smoke Detector	Terminal up lvl c rrac Markn office	Tested/Cleaned	9:09:37 AM	12/13/2019
Smoke Detector	Terminal up lvl c w wing exit @tsa office	Tested/Cleaned	9:10:16 AM	12/13/2019
Smoke Detector	Terminal up lvl c w wing hall @ stag rm	Tested/Cleaned	9:10:03 AM	12/13/2019
Smoke Detector	Terminal up lvl c w wing hall @tsa office	Tested/Cleaned	2:20:29 PM	12/12/2019
Smoke Detector	Terminal up lvl c w wing hall @tsa office	Tested/Cleaned	9:09:57 AM	12/13/2019
Smoke Detector	Terminal up lvl c w wing in storage rm	Tested/Cleaned	9:10:07 AM	12/13/2019
Smoke Detector	Terminal upper lvl b commission office hall	Tested/Cleaned	2:38:24 PM	12/12/2019
Smoke Detector	Terminal upper lvl b commission office recep	Tested/Cleaned	2:38:30 PM	12/12/2019
Smoke Detector	Terminal upper lvl b gift shop front	Tested/Cleaned	2:36:39 PM	12/12/2019
Smoke Detector	Terminal upper lvl b gift shop rear	Tested/Cleaned	2:36:54 PM	12/12/2019
Smoke Detector	Terminal upper lvl b gift shop storage	Tested/Cleaned	2:36:44 PM	12/12/2019
Smoke Detector	Terminal upper lvl b hall @ bathers & sec.	Tested/Cleaned	2:38:01 PM	12/12/2019
Smoke Detector	Terminal upper lvl b hall @ comm. office	Tested/Cleaned	2:38:43 PM	12/12/2019
Smoke Detector	Terminal upper lvl b hall @ conf. room a	Tested/Cleaned	2:38:38 PM	12/12/2019
Smoke Detector	Terminal upper lvl b hall @ gift shop	Tested/Cleaned	2:36:34 PM	12/12/2019
Smoke Detector	Terminal upper lvl b hall @ Hudson group	Tested/Cleaned	2:39:14 PM	12/12/2019
Smoke Detector	Terminal upper lvl b hall @ rm t229a	Tested/Cleaned	2:37:23 PM	12/12/2019
Smoke Detector	Terminal upper lvl b hall @ up escalator	Tested/Cleaned	2:39:20 PM	12/12/2019
Smoke Detector	Terminal upper lvl b Hudson strg rm t229b	Tested/Cleaned	2:36:59 PM	12/12/2019
Smoke Detector	Terminal upper lvl b janitor closet t225	Tested/Cleaned	9:10:33 AM	12/13/2019
Smoke Detector	Terminal upper lvl b rear hall comm. office	Tested/Cleaned	2:38:16 PM	12/12/2019
Smoke Detector	Terminal upper lvl b rrac finance office	Tested/Cleaned	2:37:19 PM	12/12/2019
Smoke Detector	Terminal upper lvl b security office	Tested/Cleaned	2:38:07 PM	12/12/2019
Smoke Detector	Terminal upper lvl mezzanine janitor room	Tested/Cleaned	9:10:37 AM	12/13/2019
Smoke Detector	Terminal upr area a concrs. elevator shaft	Tested/Cleaned	10:48:08 PM	12/11/2019
Smoke Detector	Terminal upr area a concurs. elevator lobby	Tested/Cleaned	10:48:49 PM	12/11/2019

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Smoke Detector	Terminal upr area a elv #3 1st fl lobby	Tested/Cleaned	10:49:24 PM	12/11/2019
Smoke Detector	Terminal upr area a elv #3 2nd fl lobby	Tested/Cleaned	10:49:05 PM	12/11/2019
Smoke Detector	Terminal upr area a elv #3 shaft	Tested/Cleaned	10:49:10 PM	12/11/2019
Smoke Detector	Terminal upr area a gate 2	Tested/Cleaned	2:43:09 PM	12/12/2019
Smoke Detector	Terminal upr area a gate 2	Tested/Cleaned	2:43:12 PM	12/12/2019
Smoke Detector	Terminal upr area a gate 2	Tested/Cleaned	2:43:16 PM	12/12/2019
Smoke Detector	Terminal upr area a gate 3	Tested/Cleaned	2:42:39 PM	12/12/2019
Smoke Detector	Terminal upr area a gate 3	Tested/Cleaned	2:42:43 PM	12/12/2019
Smoke Detector	Terminal upr area a gate 4	Tested/Cleaned	2:42:47 PM	12/12/2019
Smoke Detector	Terminal upr area a gate 4	Tested/Cleaned	2:42:51 PM	12/12/2019
Smoke Detector	Terminal upr area a gate 5	Tested/Cleaned	2:42:01 PM	12/12/2019
Smoke Detector	Terminal upr area a gate 6	Tested/Cleaned	2:41:57 PM	12/12/2019
Smoke Detector	Terminal upr area a McAlister's cafe	Tested/Cleaned	2:42:22 PM	12/12/2019
Smoke Detector	Terminal upr area a McAlister's seating	Tested/Cleaned	2:42:17 PM	12/12/2019
Smoke Detector	Terminal upr area a McAlister's storage	Tested/Cleaned	2:42:27 PM	12/12/2019
Smoke Detector	Terminal upr area a passenger screen	Tested/Cleaned	2:42:56 PM	12/12/2019
Smoke Detector	Terminal upr area a passenger screen	Tested/Cleaned	2:43:00 PM	12/12/2019
Smoke Detector	Terminal upr area a passenger screen	Tested/Cleaned	2:43:05 PM	12/12/2019
Smoke Detector	Terminal upr area Hudson space sales	Tested/Cleaned	2:42:08 PM	12/12/2019
Smoke Detector	Terminal upr area Hudson space sales	Tested/Cleaned	2:42:12 PM	12/12/2019
Smoke Detector	Terminal upr area Hudson space stock rm	Tested/Cleaned	2:42:31 PM	12/12/2019
Smoke Detector	Terminal upr area Hudson space stock rm	Tested/Cleaned	2:42:35 PM	12/12/2019
Smoke Detector	Terminal upr lvl c elevator shaft	Tested/Cleaned	10:50:35 PM	12/11/2019
Smoke Detector	Terminal upr lvl c freight elevator lobby	Tested/Cleaned	10:50:28 PM	12/11/2019
Device Type	Location	Service	Time	Date
<b><i>Failed/Other</i></b>				
<b>Control</b>				
Battery	Hanger 15	Tested	11:44:09 AM	12/11/2019
<b>Indicating</b>				
Horn/Strobe	Building 51 Building	Tested	11:27:06 AM	12/10/2019

**Building: ROANOKE REGIONAL AIRPORT    Control Panel: 2 - Simplex 4020**

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.*

<b>Device Type</b>	<b>Location</b>	<b>Service</b>	<b>Time</b>	<b>Date</b>
<b><i>Passed</i></b>				
<b>Control</b>				
Control Panel	Maintenance Garage main panel	Tested	10:23:14 AM	12/11/2019
Control Panel	Terminal soc rm	Tested	2:59:04 PM	12/12/2019



**Building: ROANOKE REGIONAL AIRPORT    Control Panel: 3 - Simplex 4100U**

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.*

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
<b>Control</b>				
Battery	Terminal chiller room	Tested	2:51:24 PM	12/12/2019
Battery	Terminal chiller room	Tested	2:52:17 PM	12/12/2019
Battery	Terminal closet next to TSA office	Tested	2:12:33 PM	12/12/2019
Battery	Terminal closet next to TSA office	Tested	2:12:44 PM	12/12/2019
Battery	Terminal custodian closet	Tested	1:53:47 PM	12/12/2019
Battery	Terminal custodian closet	Tested	1:54:25 PM	12/12/2019
Battery	Terminal law enforcement office	Tested	3:21:48 PM	12/12/2019
Battery	Terminal law enforcement office	Tested	3:22:05 PM	12/12/2019
Battery	Terminal stairwell east	Tested	1:59:34 PM	12/12/2019
Battery	Terminal stairwell east	Tested	2:04:18 PM	12/12/2019
Battery	Terminal stairwell west	Tested	1:45:57 PM	12/12/2019
Battery	Terminal stairwell west	Tested	1:46:13 PM	12/12/2019
Control Panel	Building 51 main panel	Tested	10:48:09 AM	12/10/2019
Control Panel	Hanger 15 main panel	Tested	11:24:07 AM	12/11/2019
Control Panel	Terminal check point	Tested	3:10:02 PM	12/12/2019
Expander Panel	Building 51 main panel	Tested	10:47:10 AM	12/10/2019

**Building: ROANOKE REGIONAL AIRPORT    Control Panel: 4 - Silent Knight 4020**

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.*

<b>Device Type</b>	<b>Location</b>	<b>Service</b>	<b>Time</b>	<b>Date</b>
<b><i>Passed</i></b>				
<b>Control</b>				
Control Panel	Hanger 14 main panel	Tested	11:23:29 AM	12/11/2019
Control Panel	Terminal law enforcement office	Tested	3:18:04 PM	12/12/2019
Special Control	Terminal chiller room	Tested/Cleaned	2:51:37 PM	12/12/2019
Special Control	Terminal closet next to TSA office	Tested/Cleaned	2:13:00 PM	12/12/2019
Special Control	Terminal custodian closet	Tested/Cleaned	1:53:53 PM	12/12/2019
Special Control	Terminal law enforcement office	Tested/Cleaned	3:20:59 PM	12/12/2019

**Building: ROANOKE REGIONAL AIRPORT    Control Panel: 5 - Simplex 4100U**

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.*

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
<b>Control</b>				
Control Panel	Terminal stairwell east	Tested	2:17:19 PM	12/12/2019

**Building: ROANOKE REGIONAL AIRPORT    Control Panel: 6 - Simplex 4100U**

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.*

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
<b>Control</b>				
Control Panel	Terminal stairwell west	Tested	1:46:24 PM	12/12/2019

**Building: ROANOKE REGIONAL AIRPORT    Control Panel: 7 - Simplex 4100U**

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.*

<b>Device Type</b>	<b>Location</b>	<b>Service</b>	<b>Time</b>	<b>Date</b>
<b><i>Passed</i></b>				
<b>Auxiliary</b>				
Roll Down Door	Maintenance Garage warehouse middle	Tested	10:45:31 PM	12/11/2019
<b>Control</b>				
Annunciator	ARFF Station front entrance	Tested	1:52:38 PM	12/10/2019
Annunciator	Maintenance Garage office	Tested	9:52:55 AM	12/11/2019
Control Panel	ARFF Station panel room	Tested	1:59:36 PM	12/10/2019

# Service Summary

Generated by: BuildingReports.com

Building: ROANOKE REGIONAL AIRPORT		
<i>The Service Summary section provides an overview of the services performed in this report.</i>		
Device Type	Service	Quantity
<b><i>Failed/Other</i></b>		
Battery	Tested	1
Horn/Strobe	Tested	1
<b>Total</b>		<b>2</b>
<b><i>Passed</i></b>		
Annunciator	Tested	3
Battery	Tested	31
Communicator	Tested	1
Control Panel	Tested	10
Duct Detector	Tested	18
Expander Panel	Tested	1
Heat Detector	Tested	85
Horn/Strobe	Tested	5
Pull Station	Tested	79
Roll Down Door	Tested	1
Smoke Detector	Tested/Cleaned	189
Special Control	Tested/Cleaned	4
<b>Total</b>		<b>427</b>
<b>Grand Total</b>		<b>429</b>

# Auxiliary Functions Testing

Generated by: BuildingReports.com

Building: ROANOKE REGIONAL AIRPORT			Control Panel: 1	
<p>The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.</p>				
Type	Location	Comment	ScanID	Simulated
<b>Passed</b>				
<b>Heat Detector</b>				
heat	Terminal upper lvl c concessions kitchen area	Passed	52328694	
heat	Terminal upper lvl c concessions serve area	Passed	52328693	
heat	Terminal upr area a macalisters cafe	Passed	52328695	
<b>Smoke Detector</b>				
Smoke Compartment	Building 51 basement electrical rm	Passed	52328907	
Smoke Compartment	Building 51 basement electrical rm	Passed	52328906	
Smoke Compartment	Building 51 basement telephone rm	Passed	52328908	
Smoke Compartment	Building 51 elevator	Passed	52328900	
Smoke Compartment	Building 51 elevator	Passed	52328901	
Smoke Compartment	Building 51 mechanical room	Passed	52328902	
Smoke Compartment	Maintenance Garage @ mezzanine	Passed	52328748	
Smoke Compartment	Maintenance Garage @ mezzanine	Passed	52328749	
Smoke Compartment	Maintenance Garage @ mezzanine	Passed	52328750	
Smoke Compartment	Maintenance Garage @ mezzanine	Passed	52328751	
Smoke Compartment	Maintenance Garage @ Parts room	Passed	52328733	
Smoke Compartment	Maintenance Garage @ Parts room	Passed	52328734	
Smoke Compartment	Maintenance Garage facility and grounds office	Passed	52328804	
Smoke Compartment	Maintenance Garage front hallway	Passed	52328808	
Smoke Compartment	Maintenance Garage front hallway @ men's room	Passed	52328803	
Smoke Compartment	Maintenance Garage front office	Passed	52328809	
Smoke Compartment	Maintenance Garage laundry room	Passed	52328805	
Smoke Compartment	Maintenance Garage lunch room	Passed	52328806	
Smoke Compartment	Maintenance Garage Mechanic office	Passed	52328757	
Smoke Compartment	Maintenance Garage mezzanine storage	Passed	52328752	
Smoke Compartment	Maintenance Garage mezzanine storage	Passed	52328753	
Smoke Compartment	Terminal Electric rm behind copy rm	Passed	52328928	
Smoke Compartment	Terminal finance office hallway	Passed	52328594	
Smoke Compartment	Terminal lwr area a	Passed	52328623	
Smoke Compartment	Terminal lwr area a	Passed	52328624	
Smoke Compartment	Terminal lwr area a	Passed	52328625	
Smoke Compartment	Terminal lwr area a ah-3 rm	Passed	52328633	
Smoke Compartment	Terminal lwr area a ah-3 rm	Passed	52328634	
Smoke Compartment	Terminal lwr area a ah-4 elec panel rm	Passed	52328628	
Smoke Compartment	Terminal lwr area a ah-4 equip rm	Passed	52328626	

**Building: ROANOKE REGIONAL  
AIRPORT**

**Control Panel: 1**

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
Smoke Compartment	Terminal lwr area a ah-4 equip rm	Passed	52328627	
Smoke Compartment	Terminal lwr area a airline ops	Passed	52328635	
Smoke Compartment	Terminal lwr area a elevator equip rm	Passed	52328629	
Smoke Compartment	Terminal lwr area a main facp soc	Passed	52328630	
Smoke Compartment	Terminal lwr area a soc rm	Passed	52328631	
Smoke Compartment	Terminal lwr area a soc server rm	Passed	52328632	
Smoke Compartment	Terminal lwr lvl b airline office	Passed	52328576	
Smoke Compartment	Terminal lwr lvl b boiler rm	Passed	52328563	
Smoke Compartment	Terminal lwr lvl b east end eds	Passed	52328573	
Smoke Compartment	Terminal lwr lvl b east end eds	Passed	52328574	
Smoke Compartment	Terminal lwr lvl b east ticket	Passed	52328555	
Smoke Compartment	Terminal lwr lvl b escalator hall	Passed	52328566	
Smoke Compartment	Terminal lwr lvl b main switch rm	Passed	52328564	
Smoke Compartment	Terminal lwr lvl b mechanical rm	Passed	52328927	
Smoke Compartment	Terminal lwr lvl b mechanical rm	Passed	52328562	
Smoke Compartment	Terminal lwr lvl b pump rm	Passed	52328565	
Smoke Compartment	Terminal lwr lvl b ticket area	Passed	52328569	
Smoke Compartment	Terminal lwr lvl b ticket area	Passed	52328570	
Smoke Compartment	Terminal lwr lvl b ticket area	Passed	52328571	
Smoke Compartment	Terminal lwr lvl b ticket area	Passed	52328572	
Smoke Compartment	Terminal lwr lvl b ticket hallway	Passed	52328575	
Smoke Compartment	Terminal lwr lvl b ticket hallway	Passed	52328577	
Smoke Compartment	Terminal lwr lvl b ticket hallway	Passed	52328578	
Smoke Compartment	Terminal lwr lvl b ticket hallway	Passed	52328579	
Smoke Compartment	Terminal lwr lvl b west end eds	Passed	52328567	
Smoke Compartment	Terminal lwr lvl b west end eds	Passed	52328568	
Smoke Compartment	Terminal lwr lvl c ambassador rm	Passed	52328603	
Smoke Compartment	Terminal lwr lvl c bag claim area	Passed	52328559	
Smoke Compartment	Terminal lwr lvl c bag claim area	Passed	52328560	
Smoke Compartment	Terminal lwr lvl c bag claim area	Passed	52328561	
Smoke Compartment	Terminal lwr lvl c concession area	Passed	52328584	
Smoke Compartment	Terminal lwr lvl c concessions @drink Mach.	Passed	52328581	
Smoke Compartment	Terminal lwr lvl c main elevator	Passed	52328585	
Smoke Compartment	Terminal lwr lvl c main elevator	Passed	52328580	
Smoke Compartment	Terminal lwr lvl c restur. front area	Passed	52328582	
Smoke Compartment	Terminal lwr lvl c restur. front area	Passed	52328583	
Smoke Compartment	Terminal lwr lvl c west balcony hall	Passed	52328586	
Smoke Compartment	Terminal lwr lvl c west balcony hall	Passed	52328587	
Smoke Compartment	Terminal lwr lvl c west balcony hall	Passed	52328588	
Smoke Compartment	Terminal lwr lvl c west elevator hall	Passed	52328602	
Smoke Compartment	Terminal lwr lvl c west wing tsa offices	Passed	52328589	
Smoke Compartment	Terminal lwr lvl c west wing tsa offices	Passed	52328590	
Smoke Compartment	Terminal lwr lvl c west wing tsa offices	Passed	52328591	
Smoke Compartment	Terminal up lvl c concession kitchen area	Passed	52328600	
Smoke Compartment	Terminal up lvl c hallway fiancé west	Passed	52328593	
Smoke Compartment	Terminal up lvl c hallway finance east	Passed	52328595	



**Building: ROANOKE REGIONAL  
AIRPORT**

**Control Panel: 1**

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
Smoke Compartment	Terminal up lvl c main elevator lobby	Passed	52328811	
Smoke Compartment	Terminal up lvl c main elevator shaft	Passed	52328812	
Smoke Compartment	Terminal up lvl c rrac Markn office	Passed	52328592	
Smoke Compartment	Terminal up lvl c w wing exit @tsa office	Passed	52328601	
Smoke Compartment	Terminal up lvl c w wing hall @ stag rm	Passed	52328598	
Smoke Compartment	Terminal up lvl c w wing hall @tsa office	Passed	52325897	
Smoke Compartment	Terminal up lvl c w wing hall @tsa office	Passed	52328596	
Smoke Compartment	Terminal up lvl c w wing in storage rm	Passed	52328599	
Smoke Compartment	Terminal upper lvl b commission office hall	Passed	52328614	
Smoke Compartment	Terminal upper lvl b commission office recep	Passed	52328615	
Smoke Compartment	Terminal upper lvl b gift shop front	Passed	52328605	
Smoke Compartment	Terminal upper lvl b gift shop rear	Passed	52328607	
Smoke Compartment	Terminal upper lvl b gift shop storage	Passed	52328606	
Smoke Compartment	Terminal upper lvl b hall @ bathers & sec.	Passed	52328611	
Smoke Compartment	Terminal upper lvl b hall @ comm. office	Passed	52328616	
Smoke Compartment	Terminal upper lvl b hall @ conf. room a	Passed	52328617	
Smoke Compartment	Terminal upper lvl b hall @ gift shop	Passed	52328604	
Smoke Compartment	Terminal upper lvl b hall @ Hudson group	Passed	52328618	
Smoke Compartment	Terminal upper lvl b hall @ rm t229a	Passed	52328610	
Smoke Compartment	Terminal upper lvl b hall @ up escalator	Passed	52328619	
Smoke Compartment	Terminal upper lvl b Hudson strg rm t229b	Passed	52328608	
Smoke Compartment	Terminal upper lvl b janitor closet t225	Passed	52328620	
Smoke Compartment	Terminal upper lvl b rear hall comm. office	Passed	52328613	
Smoke Compartment	Terminal upper lvl b rrac finance office	Passed	52328609	
Smoke Compartment	Terminal upper lvl b security office	Passed	52328612	
Smoke Compartment	Terminal upper lvl mezzanine janitor room	Passed	52328621	
Smoke Compartment	Terminal upr area a gate 2	Passed	52328652	
Smoke Compartment	Terminal upr area a gate 2	Passed	52328653	
Smoke Compartment	Terminal upr area a gate 2	Passed	52328654	
Smoke Compartment	Terminal upr area a gate 3	Passed	52328645	
Smoke Compartment	Terminal upr area a gate 3	Passed	52328646	
Smoke Compartment	Terminal upr area a gate 4	Passed	52328647	
Smoke Compartment	Terminal upr area a gate 4	Passed	52328648	
Smoke Compartment	Terminal upr area a gate 5	Passed	52328637	
Smoke Compartment	Terminal upr area a gate 6	Passed	52328636	
Smoke Compartment	Terminal upr area a McAlister's cafe	Passed	52328641	
Smoke Compartment	Terminal upr area a McAlister's seating	Passed	52328640	
Smoke Compartment	Terminal upr area a McAlister's storage	Passed	52328642	
Smoke Compartment	Terminal upr area a passenger screen	Passed	52328649	
Smoke Compartment	Terminal upr area a passenger screen	Passed	52328650	
Smoke Compartment	Terminal upr area a passenger screen	Passed	52328651	
Smoke Compartment	Terminal upr area Hudson space sales	Passed	52328638	
Smoke Compartment	Terminal upr area Hudson space sales	Passed	52328639	
Smoke Compartment	Terminal upr area Hudson space stock rm	Passed	52328643	
Smoke Compartment	Terminal upr area Hudson space stock rm	Passed	52328644	

Building: ROANOKE REGIONAL  
AIRPORT

Control Panel: 7 - Simplex 4100U

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Roll Down Door</b>				
	Maintenance Garage warehouse middle	Passed	52328878	<input type="checkbox"/>

# Battery & Power Supply Testing

Generated by: BuildingReports.com

## Building: ROANOKE REGIONAL AIRPORT Control Panel: 1

The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.

Battery							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
<b>Passed</b>							
Sealed Lead Acid	ARFF Station main panel	12	12			7.8	12
Sealed Lead Acid	ARFF Station main panel	12	12			7.8	12
Sealed Lead Acid	ARFF Station main panel	7	12			4.55	11
Sealed Lead Acid	ARFF Station main panel	7	12			4.55	11
Sealed Lead Acid	Building 51 main panel	18	12				17
Sealed Lead Acid	Building 51 main panel	18	12				21.2
Sealed Lead Acid	Building 51 nac	7	12			4.55	12
Sealed Lead Acid	Building 51 nac	7	12			4.55	11
Sealed Lead Acid	Hanger 14	7	12			4.55	7.9
Sealed Lead Acid	Hanger 14	8.5	12			4.55	8
Sealed Lead Acid	Hanger 15	8.5	12			5.525	6
Sealed Lead Acid	Maintenance Garage main panel	18	12			11.7	15
Sealed Lead Acid	Maintenance Garage main panel	18	12			11.7	14
Sealed Lead Acid	Terminal check point	55.0	12			35.75	38
	Terminal check point	55.0	12			35.75	38
	Terminal law enforcement office	55.0	12			35.75	38
	Terminal law enforcement office	55.0	12			35.75	38
Sealed Lead Acid	Terminal soc rm	55.0	12			35.75	38
Sealed Lead Acid	Terminal soc rm	55.0	12			35.75	38
<b>Failed/Other</b>							
Sealed Lead Acid	Hanger 15	8.5	12			5.525	4.6

## Building: ROANOKE REGIONAL AIRPORT Control Panel: 3 - Simplex 4100U

The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.

Battery							
Type	Location	Rated	Rated	Pre	Post	Min	Tested

	Ah	Volts	Test	Test	Ah	Ah
<i>Passed</i>						
Terminal chiller room	12	12				13
Terminal chiller room	12	12				13
Terminal closet next to TSA office	12	12				12
Terminal closet next to TSA office	12	12				12
Terminal custodian closet	12	12			7.8	12
Terminal custodian closet	12	12			7.8	13
Terminal law enforcement office	12	12				11
Terminal law enforcement office	12	12				12
Terminal stairwell east	55	12			35.75	37
Terminal stairwell east	55	12			35.75	38
Terminal stairwell west	55	12				38
Terminal stairwell west	55	12				57

# Inventory & Warranty Report

Generated by: *BuildingReports.com*

<b>Building: ROANOKE REGIONAL AIRPORT</b>	<b>Control Panel: 1</b>
---	-------------------------

*The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.*

Device or Type	Category	% of Inventory	Quantity
Pull Station	Initiating	18.41%	79
Annunciator	Control	0.70%	3
Duct Detector	Initiating	4.20%	18
Smoke Detector	Initiating	44.06%	189
Expander Panel	Control	0.23%	1
Battery	Control	7.46%	32
Control Panel	Control	2.33%	10
Horn/Strobe	Indicating	1.40%	6
Heat Detector	Initiating	19.81%	85
Communicator	Control	0.23%	1
Roll Down Door	Auxiliary	0.23%	1
Special Control	Control	0.93%	4

Type	Qty	Model #	Description	Install Date
<b><i>In Service - 1 Year to 2 Years</i></b>				
Battery	3			11/27/2018
Battery	17		Sealed Lead Acid	11/27/2018
Horn/Strobe	3			11/27/2018
Smoke Detector	4			11/27/2018
<b>ESL</b>				
Pull Station	4	103-01	Keyed	11/27/2018
<b>Fire-Lite</b>				
Annunciator	1			11/27/2018
Pull Station	3	103-01	Keyed	11/27/2018
<b>Honeywell</b>				
Communicator	1	vista-128fbpn	Digital Communicator	11/27/2018
<b>innovair</b>				
Duct Detector	5		Photoelectric	11/27/2018
<b>Silent Knight</b>				
Pull Station	2		Keyed	11/27/2018
<b>Simplex</b>				
Duct Detector	13	4098-9756	Photoelectric	11/27/2018
Heat Detector	79		Rate-of-Rise	11/27/2018
Heat Detector	6	4098-9733	Rate-of-Rise	11/27/2018
Horn/Strobe	3			11/27/2018

Pull Station	6		Keyed	11/27/2018
Pull Station	64	596B	Keyed	11/27/2018
Smoke Detector	49	4098-9714		11/27/2018
Smoke Detector	12	4098-9714	Photoelectric	11/27/2018
	0			
Smoke Detector	16	596B		11/27/2018

**Building: ROANOKE REGIONAL AIRPORT** **Control Panel: 2 - Simplex 4020**

*The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.*

Type	Qty	Model #	Description	Install Date
<b><i>In Service - 1 Year to 2 Years</i></b>				
<b>Simplex</b>				
Control Panel	1	4020		11/27/2018
Control Panel	1	4100U		11/27/2018

**Building: ROANOKE REGIONAL AIRPORT** **Control Panel: 3 - Simplex 4100U**

*The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.*

Type	Qty	Model #	Description	Install Date
<b><i>In Service - 1 Year to 2 Years</i></b>				
<b>Fire-Lite</b>				
Control Panel	1	MS-9200UDLS		11/27/2018
Expander Panel	1	FCPS-24FS8		11/27/2018
<b>Silent Knight</b>				
Control Panel	1	4020		11/27/2018
<b>Simplex</b>				
Battery	12			11/27/2018
Control Panel	1	4100U		11/27/2018

**Building: ROANOKE REGIONAL AIRPORT** **Control Panel: 4 - Silent Knight 4020**

*The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.*

Type	Qty	Model #	Description	Install Date
<b><i>In Service - 1 Year to 2 Years</i></b>				
<b>Silent Knight</b>				
Control Panel	1	4020		11/27/2018

<b>Simplex</b>				
Control Panel	1	4100U		11/27/2018
Special Control	4	409IDNET	NAC	11/27/2018
<b>Building: ROANOKE REGIONAL AIRPORT</b>			<b>Control Panel: 5 - Simplex 4100U</b>	
<i>The Inventory &amp; Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.</i>				
Type	Qty	Model #	Description	Install Date
<b><i>In Service - 1 Year to 2 Years</i></b>				
<b>Simplex</b>				
Control Panel	1	4100U		11/27/2018
<b>Building: ROANOKE REGIONAL AIRPORT</b>			<b>Control Panel: 6 - Simplex 4100U</b>	
<i>The Inventory &amp; Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.</i>				
Type	Qty	Model #	Description	Install Date
<b><i>In Service - 1 Year to 2 Years</i></b>				
<b>Simplex</b>				
Control Panel	1	4100U		11/27/2018
<b>Building: ROANOKE REGIONAL AIRPORT</b>			<b>Control Panel: 7 - Simplex 4100U</b>	
<i>The Inventory &amp; Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.</i>				
Type	Qty	Model #	Description	Install Date
<b><i>In Service - 1 Year to 2 Years</i></b>				
Roll Down Door	1			11/27/2018
<b>Simplex</b>				
Annunciator	2		LCD Display	11/27/2018
Control Panel	1	4100U		11/27/2018

# Zone Address Report

Generated by: BuildingReports.com

**Building: ROANOKE REGIONAL AIRPORT    Control Panel: 1**

*The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.*

Address	Device Type	Location	Type	ScanID
M1-1	Smoke Detector	Terminal lwr area a main facp soc	Photoelectric	52328630
M1-2	Duct Detector	Terminal lwr area a ah-3 rm	Photoelectric	52328667
M1-3	Pull Station	Terminal lwr area a gate 6 hall exit	Keyed	52328540
M1-4	Smoke Detector	Terminal lwr area a ah-3 rm	Photoelectric	52328634
M1-7	Smoke Detector	Terminal lwr area a elev 5 and 6 equip rm		52328672
M1-8	Heat Detector	Terminal lwr area a elevator 5 and 6 equip rm	Rate-of-Rise	52328673
M1-16	Heat Detector	Terminal lwr area a elevator 5 and 6 pit	Rate-of-Rise	52328670
M1-17	Smoke Detector	Terminal lwr area a elevator 5 and 6 pit		52328671
M1-18	Pull Station	Terminal lwr area a airline ops	Keyed	52328542
M1-19	Smoke Detector	Terminal lwr area a airline ops	Photoelectric	52328635
M1-20	Pull Station	Terminal lwr area a gate 5 stairway exit	Keyed	52328541
M1-21	Smoke Detector	Terminal lwr area a ah-3 rm	Photoelectric	52328633
M1-22	Duct Detector	Terminal lwr area a ah-3 rm	Photoelectric	52328665
M1-23	Smoke Detector	Terminal lwr area a soc server rm	Photoelectric	52328632
M1-27	Smoke Detector	Terminal lwr area a soc rm	Photoelectric	52328631
M1-28	Pull Station	Terminal lwr area a exit	Keyed	52328539
M1-30	Pull Station	Terminal lwr area a exit	Keyed	52328535
M1-31	Smoke Detector	Terminal lwr area a	Photoelectric	52328624
M1-32	Smoke Detector	Terminal lwr area a elevator equip rm	Photoelectric	52328629
M1-33	Smoke Detector	Terminal lwr area a ah-4 elec panel rm	Photoelectric	52328628
M1-34	Duct Detector	Terminal lwr area a ah-4 equip rm	Photoelectric	52328664
M1-35	Pull Station	Terminal lwr area a gate 3 exit	Keyed	52328533
M1-36	Pull Station	Terminal lwr area a commuter gate	Keyed	52328525
M1-37	Pull Station	Terminal lwr area a commuter gate	Keyed	52328526
M1-38	Smoke Detector	Terminal lwr area a commuter gate		52328679
M1-39	Smoke Detector	Terminal lwr area a ah-4 equip rm	Photoelectric	52328627
M1-40	Smoke Detector	Terminal upr area a elv #3 1st fl lobby		52328678
M1-41	Smoke Detector	Terminal elevator #3 pit		52328683
M1-42	Heat Detector	Terminal elevator #3 pit	Rate-of-Rise	52328682
M1-43	Pull Station	Terminal lwr area a commuter stairwell	Keyed	52328524
M1-49	Heat Detector	Terminal upr area a elevator #3 equip rm	Rate-of-Rise	52328681
M1-50	Smoke Detector	Terminal lwr area a elev #3 equip rm		52328680
M1-51	Pull Station	Terminal lwr area a gate 2 stairway	Keyed	52328537
M1-52	Duct Detector	Terminal lwr area a ah-4 equip rm	Photoelectric	52328663
M1-53	Smoke Detector	Terminal lwr area a ah-4 equip rm	Photoelectric	52328626
M1-54	Pull Station	Terminal lwr area a ah-4 equip rm	Keyed	52328534
M1-55	Smoke Detector	Terminal lwr area a	Photoelectric	52328625
M1-56	Smoke Detector	Terminal lwr area a	Photoelectric	52328623
M1-57	Pull Station	Terminal lwr area a exit	Keyed	52328536
M1-59	Pull Station	Terminal lwr area a soc exit	Keyed	52328538



M1-61	Pull Station	Terminal upr area a gate 5a exit	Keyed	52328528
M1-62	Smoke Detector	Terminal upr area a gate 5	Photoelectric	52328637
M1-63	Smoke Detector	Terminal upr area a concurs. elevator lobby		52328674
M1-64	Heat Detector	Terminal upr area a concurs. elevator shaft	Rate-of-Rise	52328669
M1-65	Smoke Detector	Terminal upr area a concurs. elevator shaft		52328668
M1-66	Smoke Detector	Terminal upr area a gate 6	Photoelectric	52328636
M1-67	Pull Station	Terminal upr area a exit	Keyed	52328529
M1-68	Smoke Detector	Terminal upr area a McAlister's cafe	Photoelectric	52328641
M1-69	Smoke Detector	Terminal upr area a gate 4	Photoelectric	52328647
M1-70	Smoke Detector	Terminal upr area a gate 4	Photoelectric	52328648
M1-71	Pull Station	Terminal upr area a exit	Keyed	52328530
M1-72	Smoke Detector	Terminal upr area a elv #3 2nd fl lobby		52328675
M1-73	Pull Station	Terminal upr level a concurs. elevator	Keyed	52328527
M1-74	Heat Detector	Terminal upr area a elevator #3 shaft	Rate-of-Rise	52328677
M1-75	Smoke Detector	Terminal upr area a elv #3 shaft		52328676
M1-77	Smoke Detector	Terminal upr area a gate 2	Photoelectric	52328652
M1-78	Smoke Detector	Terminal upr area a gate 2	Photoelectric	52328653
M1-79	Smoke Detector	Terminal upr area a gate 2	Photoelectric	52328654
M1-80	Pull Station	Terminal upr area a exit	Keyed	52328532
M1-81	Smoke Detector	Terminal upr area a passenger screen	Photoelectric	52328651
M1-82	Smoke Detector	Terminal upr area a passenger screen	Photoelectric	52328650
M1-83	Smoke Detector	Terminal upr area a passenger screen	Photoelectric	52328649
M1-84	Pull Station	Terminal upr area a exit	Keyed	52328531
M1-85	Smoke Detector	Terminal upr area a gate 3	Photoelectric	52328646
M1-86	Smoke Detector	Terminal upr area a gate 3	Photoelectric	52328645
M1-93	Duct Detector	Terminal lwr area a ah-3 rm	Photoelectric	52328666
M1-95	Smoke Detector	Terminal upr area Hudson space sales	Photoelectric	52328638
M1-96	Smoke Detector	Terminal upr area Hudson space sales	Photoelectric	52328639
M1-97	Smoke Detector	Terminal upr area Hudson space stock rm	Photoelectric	52328644
M1-98	Smoke Detector	Terminal upr area Hudson space stock rm	Photoelectric	52328643
M1-99	Heat Detector	Terminal upr area a macalisters cafe	Rate-of-Rise	52328695
M1-100	Smoke Detector	Terminal upr area a McAlister's storage	Photoelectric	52328642
M1-101	Smoke Detector	Terminal upr area a McAlister's seating	Photoelectric	52328640
M2-1	Smoke Detector	Terminal lower area b east stairwell		52328819
M2-2	Pull Station	Terminal Lwr area B east stairway	Keyed	52328505
M2-3	Smoke Detector	Terminal lwr lvl b east ticket		52328558
M2-4	Pull Station	Terminal Lwr area B east lobby	Keyed	52328504
M2-5	Smoke Detector	Terminal lwr lvl b east ticket		52328557
M2-6	Pull Station	Terminal Lwr area B east lobby	Keyed	52328503
M2-7	Smoke Detector	Terminal lwr lvl b east ticket		52328556
M2-8	Smoke Detector	Terminal lwr lvl b east ticket		52328555
M2-9	Smoke Detector	Terminal lwr lvl b east ticket		52328554
M2-10	Smoke Detector	Terminal lwr lvl b east ticket		52328553
M2-11	Smoke Detector	Terminal lwr lvl b east ticket		52328552
M2-12	Smoke Detector	Terminal lwr lvl b east ticket		52328551
M2-14	Smoke Detector	Terminal lwr lvl b escalator hall	Photoelectric	52328566
M2-15	Pull Station	Terminal Lwr lvl B ticket area	Keyed	52328510
M2-16	Smoke Detector	Terminal Electric rm behind copy rm	Photoelectric	52328928

M2-16	Smoke Detector	Terminal lwr lvl b ticket area	Photoelectric	52328569
M2-17	Smoke Detector	Terminal lwr lvl b ticket area	Photoelectric	52328570
M2-18	Smoke Detector	Terminal lwr lvl b ticket area	Photoelectric	52328571
M2-19	Smoke Detector	Terminal lwr lvl b ticket area	Photoelectric	52328572
M2-20	Pull Station	Terminal Lwr lvl B ticket area	Keyed	52328506
M2-21	Smoke Detector	Terminal lwr lvl b ticket hallway	Photoelectric	52328575
M2-22	Smoke Detector	Terminal lwr lvl b airline office	Photoelectric	52328576
M2-23	Smoke Detector	Terminal lwr lvl b ticket hallway	Photoelectric	52328577
M2-24	Pull Station	Terminal Lwr lvl B ticket hallway	Keyed	52328508
M2-25	Pull Station	Terminal Lwr lvl B ticket hallway	Keyed	52328509
M2-26	Smoke Detector	Terminal lwr lvl b ticket hallway	Photoelectric	52328578
M2-27	Smoke Detector	Terminal lwr lvl b ticket hallway	Photoelectric	52328579
M2-29	Smoke Detector	Terminal lwr lvl b pump rm	Photoelectric	52328565
M2-31	Smoke Detector	Terminal lwr lvl b mechanical rm	Photoelectric	52328562
M2-31	Smoke Detector	Terminal lwr lvl b mechanical rm	Photoelectric	52328927
M2-32	Pull Station	Terminal lwr lvl b mechanical rm	Keyed	52328622
M2-33	Pull Station	Terminal Lwr lvl B main switch rm	Keyed	52328513
M2-34	Smoke Detector	Terminal lwr lvl b main switch rm	Photoelectric	52328564
M2-35	Smoke Detector	Terminal lwr lvl b boiler rm	Photoelectric	52328563
M2-36	Pull Station	Terminal Lwr lvl B bag make up	Keyed	52328511
M2-50	Pull Station	Terminal Lwr lvl B ticket hallway	Keyed	52328507
M2-51	Pull Station	Terminal upr lvl b stairs @comm. office	Keyed	52328521
M2-52	Smoke Detector	Terminal upper lvl b hall @ comm. office	Photoelectric	52328616
M2-53	Smoke Detector	Terminal upper lvl b hall @ conf. room a	Photoelectric	52328617
M2-55	Smoke Detector	Terminal upper lvl b hall @ bathers & sec.	Photoelectric	52328611
M2-56	Smoke Detector	Terminal upper lvl b janitor closet t225	Photoelectric	52328620
M2-57	Smoke Detector	Terminal upper lvl b Hudson strg rm t229b	Photoelectric	52328608
M2-58	Smoke Detector	Terminal upper lvl b hall @ Hudson group	Photoelectric	52328618
M2-59	Smoke Detector	Terminal upper lvl b gift shop storage	Photoelectric	52328606
M2-60	Smoke Detector	Terminal upper lvl b hall @ up escalator	Photoelectric	52328619
M2-61	Pull Station	Terminal upr lvl b hall @ up escalator	Keyed	52328520
M2-62	Smoke Detector	Terminal upper lvl b gift shop front	Photoelectric	52328605
M2-63	Smoke Detector	Terminal upper lvl b hall @ gift shop	Photoelectric	52328604
M2-64	Pull Station	ARFF Station exit door @ Decon 149	Keyed	52328860
M2-64	Pull Station	ARFF Station exit door @ kitchen	Keyed	52328848
M2-64	Pull Station	ARFF Station exit door rear	Keyed	52328859
M2-64	Pull Station	ARFF Station front entrance	Keyed	52328856
M2-64	Pull Station	ARFF Station outside storage	Keyed	52328861
M2-64	Pull Station	ARFF Station side exit door	Keyed	52328837
M2-64	Pull Station	ARFF Station side exit door @ dorm rm 133 hallway	Keyed	52328845
M2-64	Pull Station	Maintenance Garage @ back door exit	Keyed	52328764
M2-64	Pull Station	Maintenance Garage @ back side door exit	Keyed	52328763
M2-64	Pull Station	Maintenance Garage @ middle door exit	Keyed	52328762
M2-64	Pull Station	Maintenance Garage @ parts room exit	Keyed	52328760
M2-64	Pull Station	Maintenance Garage @ side door exit	Keyed	52328761
M2-64	Pull Station	Maintenance Garage @side roll up door	Keyed	52328758
M2-64	Pull Station	Maintenance Garage front roll up door	Keyed	52328756
M2-64	Pull Station	Maintenance Garage mezzanine storage	Keyed	52328754

M2-64	Pull Station	Maintenance Garage storage room exit	Keyed	52328759
M2-64	Pull Station	Terminal up lvl b hall @ gift shop	Keyed	5232523
M2-65	Smoke Detector	Terminal upper lvl b rrac finance office	Photoelectric	52328609
M2-66	Smoke Detector	Terminal upper lvl b gift shop rear	Photoelectric	52328607
M2-68	Smoke Detector	Terminal upper lvl b hall @ rm t229a	Photoelectric	52328610
M2-69	Pull Station	Terminal upr lvl b rear hall comm. office	Keyed	52328522
M2-70	Smoke Detector	Terminal upper lvl b security office	Photoelectric	52328612
M2-72	Smoke Detector	Terminal upper lvl b rear hall comm. office	Photoelectric	52328613
M2-73	Smoke Detector	Terminal upper lvl b commission office hall	Photoelectric	52328614
M2-74	Smoke Detector	Terminal upper lvl b commission office recep	Photoelectric	52328615
M2-76	Duct Detector	Terminal area b penthouse east	Photoelectric	52328660
M2-77	Smoke Detector	Terminal area b penthouse east		52328659
M2-78	Duct Detector	Terminal area b penthouse east	Photoelectric	52328662
M2-79	Duct Detector	Terminal area b penthouse east	Photoelectric	52328661
M2-245	Pull Station	Terminal Lwr lvl B bag east make up exit	Keyed	52328512
M2-246	Smoke Detector	Terminal lwr lvl b east end eds	Photoelectric	52328574
M2-247	Smoke Detector	Terminal lwr lvl b east end eds	Photoelectric	52328573
M2-248	Smoke Detector	Terminal lwr lvl b west end eds	Photoelectric	52328568
M2-250	Smoke Detector	Terminal lwr lvl b west end eds	Photoelectric	52328567
M3-1	Heat Detector	Terminal lwr lvl c freight elevator rm	Rate-of-Rise	52328689
M3-2	Smoke Detector	Terminal lwr lvl c freight elevator rm		52328688
M3-3	Pull Station	Terminal Lwr lvl c west hallway	Keyed	52328514
M3-9	Pull Station	Terminal Lwr lvl c west hallway	Keyed	52328515
M3-10	Smoke Detector	Terminal lwr lvl c west freight elevator lobby		52328684
M3-13	Smoke Detector	Terminal lwr lvl c west elevator hall	Photoelectric	52328602
M3-14	Smoke Detector	Terminal lwr lvl c t102 west		52328543
M3-15	Pull Station	Terminal Lower lvl C 102 west @ T157	Keyed	52328497
M3-16	Smoke Detector	Terminal lwr lvl c t102 west		52328544
M3-17	Smoke Detector	Terminal lwr lvl c t102 west		52328545
M3-18	Pull Station	Terminal Lower lvl C 102 west @ T156	Keyed	52328498
M3-19	Smoke Detector	Terminal lwr lvl c t102 west		52328546
M3-20	Smoke Detector	Terminal lwr lvl c t102 west		52328547
M3-21	Smoke Detector	Terminal lwr lvl c t102 west		52328548
M3-22	Smoke Detector	Terminal lwr lvl c t102 west		52328549
M3-23	Smoke Detector	Terminal lwr lvl c t102 west		52328550
M3-24	Pull Station	Terminal Lower lvl C T102 west	Keyed	52328501
M3-25	Smoke Detector	Terminal lower lvl c T102 west elev lobby		52328814
M3-27	Smoke Detector	Terminal upper lvl mezzanine janitor room	Photoelectric	52328621
M3-33	Smoke Detector	Terminal lower lvl c main elevator. control rm		52328815
M3-34	Heat Detector	Terminal up lvl c main elevator control room	Rate-of-Rise	52328816
M3-40	Pull Station	Terminal Lower lvl C Bag claim area	Keyed	52328500
M3-41	Smoke Detector	Terminal lwr lvl c bag claim area	Photoelectric	52328561
M3-42	Smoke Detector	Terminal lwr lvl c bag claim area	Photoelectric	52328560
M3-43	Smoke Detector	Terminal lwr lvl c bag claim area	Photoelectric	52328559
M3-44	Pull Station	Terminal Lower lvl C Bag claim area	Keyed	52328499

M3-46	Smoke Detector	Terminal lwr lvl c ambassador rm	Photoelectric	52328603
M3-48	Pull Station	Terminal upr lvl c rest. kitchen hall	Keyed	52328517
M3-49	Pull Station	Terminal Lwr lvl c secr/l'd hallway	Keyed	52328516
M3-50	Smoke Detector	Terminal upr lvl c freight elevator lobby		52328690
M3-51	Smoke Detector	Terminal upr lvl c elevator shaft		52328691
M3-52	Heat Detector	Terminal upper lvl c elevator shaft	Rate-of-Rise	52328692
M3-53	Pull Station	Terminal upr lvl c west balcony hall	Keyed	52328518
M3-54	Smoke Detector	Terminal lwr lvl c west balcony hall	Photoelectric	52328588
M3-55	Smoke Detector	Terminal up lvl c rrac Markn office	Photoelectric	52328592
M3-57	Smoke Detector	Terminal lwr lvl c west balcony hall	Photoelectric	52328587
M3-58	Smoke Detector	Terminal lwr lvl c west balcony hall	Photoelectric	52328586
M3-59	Smoke Detector	Terminal up lvl c concession kitchen area	Photoelectric	52328600
M3-60	Smoke Detector	Terminal lwr lvl c concession area	Photoelectric	52328584
M3-61	Pull Station	Terminal upr lvl c rest. kitchen hall	Keyed	52328519
M3-62	Smoke Detector	Terminal lwr lvl c main elevator	Photoelectric	52328585
M3-63	Smoke Detector	Terminal up lvl c main elevator shaft	Photoelectric	52328812
M3-64	Heat Detector	Terminal up lvl c main elevator shaft	Rate-of-Rise	52328813
M3-65	Smoke Detector	Terminal up lvl c main elevator lobby	Photoelectric	52328811
M3-66	Smoke Detector	Terminal lwr lvl c main elevator	Photoelectric	52328580
M3-67	Smoke Detector	Terminal lwr lvl c restr. front area	Photoelectric	52328582
M3-68	Smoke Detector	Terminal lwr lvl c restr. front area	Photoelectric	52328583
M3-69	Smoke Detector	Terminal up lvl c hallway finance east	Photoelectric	52328595
M3-71	Heat Detector	Terminal main elevator pit	Rate-of-Rise	52328818
M3-71	Smoke Detector	Terminal main elevator pit		52328817
M3-73	Pull Station	Terminal B sec main entry @ revolving drs	Keyed	52328502
M3-74	Smoke Detector	Terminal lwr lvl c west wing tsa offices	Photoelectric	52328591
M3-75	Duct Detector	Terminal penthouse lvl c	Photoelectric	52328658
M3-76	Smoke Detector	Terminal penthouse lvl c		52328655
M3-77	Duct Detector	Terminal penthouse lvl c	Photoelectric	52328656
M3-78	Duct Detector	Maintenance Garage @ warehouse center door	Photoelectric	52328765
M3-78	Duct Detector	Maintenance Garage mezzanine storage	Photoelectric	52328755
M3-78	Duct Detector	Terminal penthouse lvl c	Photoelectric	52328657
M3-83	Smoke Detector	Terminal lwr lvl c concessions @drink Mach.	Photoelectric	52328581
M3-84	Heat Detector	Terminal upper lvl c concessions serve area	Rate-of-Rise	52328693
M3-86	Heat Detector	Terminal upper lvl c concessions kitchen area	Rate-of-Rise	52328694
M3-87	Smoke Detector	Terminal lwr lvl c west wing tsa offices	Photoelectric	52328590
M3-88	Smoke Detector	Terminal lwr lvl c west wing tsa offices	Photoelectric	52328589
M3-89	Smoke Detector	Terminal up lvl c w wing hall @tsa office	Photoelectric	52328597
M3-90	Smoke Detector	Terminal up lvl c w wing hall @tsa office	Photoelectric	52328596
M3-91	Smoke Detector	Terminal up lvl c w wing exit @tsa office	Photoelectric	52328601
M3-92	Smoke Detector	Terminal up lvl c w wing hall @ stag rm	Photoelectric	52328598
M3-93	Smoke Detector	Terminal up lvl c w wing in storage rm	Photoelectric	52328599
M3-95	Smoke Detector	Terminal finance office hallway	Photoelectric	52328594
M3-95	Smoke Detector	Terminal up lvl c hallway fiancé west	Photoelectric	52328593
M3-98	Smoke Detector	Terminal freight elevator area c pit		52328685
M3-99	Heat Detector	Terminal freight elevator area c pit	Rate-of-Rise	52328686